



FIRE MARSHAL'S OFFICE

**MOBILE FOOD VEHICLE INSPECTION CHECKLIST**

Date: \_\_\_\_\_ Time of Inspection: \_\_\_\_\_

Business Name: \_\_\_\_\_

Vehicle Representative: \_\_\_\_\_

Address: \_\_\_\_\_

Contact Number: \_\_\_\_\_ Email: \_\_\_\_\_

License Plate No.: \_\_\_\_\_

DHEC Inspection Date: \_\_\_\_\_ Business License Number: \_\_\_\_\_

**FIRE EXTINGUISHERS:**

- 2A10BC       3A40BC       Inspected per NFPA 10       Mounted       Accessible
- Class K Extinguisher       Inspected per NFPA 10       Mounted       Accessible

**LPG (Propane):**

- L.P. Gas containers shall be located and secured on the exterior of vehicle.  
*Not to be located on roof, inside passenger compartment, or extend further than the rear bumper and shall be protected from vehicle collision.*
- "NO SMOKING" sign posted with a minimum of 4-inch lettering above propane bottle.
- Hose used to pipe L.P. Gas must be Underwriter Laboratories (UL) or FM listed (marked 350 psi working pressure)
- Couplings, fittings, and other deices meet UL or FM requirements.
- LPG tanks are to be located outside the vehicle with a minimum 5 feet from primary means of egress.
- Carbon Monoxide (CO) detector located in vehicle utilizing fuel burning appliances.

**TYPE II HOOD / FIRE SUPPRESSION SYSTEM:**

- Type II Hood cleaned with record of cleaning verified.
- Fire Suppression System serviced with record of service verified.

**GENERATOR:**

- Refueling of generators to be performed in an approved location not less than 20 feet from vehicle.
- Fuel to be stored away from vehicle, no less than 20 feet, or in approved flammable liquid safety container.
- Storage is in an approved location (secured from movement).
- Generators shall be grounded in an approved method.
- Generators shall not be refueled in areas occupied by the public.
- Generators shall be caged or fenced off to prevent public access in approved manner.
- A minimum 2A10BC extinguisher shall be located a minimum of 20 feet from generator while refueling.

**GENERAL FIRE SAFETY:**

- Installation of electrical equipment shall comply with the Electrical Codes NFPA 70 and NEC.
- Aisle-way on interior of vehicle kept clear of storage and combustibile materials.
- Exit door latch mechanism(s) shall be operable by hand.

Approved       Disapproved

Inspected by: \_\_\_\_\_ Date: \_\_\_\_\_

Vehicle Representative: \_\_\_\_\_ Date: \_\_\_\_\_

**NOTE:** This inspection form entitles the owner/operator to operate on Citadel property only. This form does NOT permit the owner to operate on any other state, county, city, or private property.