



THE CITADEL

Solicitation Number	IFB 21025-SB
Addendum #	1
Date Issued	May 7, 2021
Procurement Officer	Scott Brechtel
Phone	843-953-2737
E-Mail Address	sbrechte@citadel.edu

SOLICITATION TITLE: HVAC Unit and Air Filter Maintenance

TYPE OF ADDENDUM:

- Change or clarification to the Solicitation's specifications, requirements, or scope of work.
- Questions posed regarding the Solicitation and their respective answers by The Citadel.

QUESTIONS FROM OFFERORS - AMENDMENT (JUN 2017)

THE SOLICITATION IS AMENDED AS PROVIDED HEREIN. INFORMATION OR CHANGES RESULTING FROM QUESTIONS WILL BE SHOWN IN A QUESTION-AND-ANSWER FORMAT. ALL QUESTIONS RECEIVED HAVE BEEN REPRINTED BELOW. THE "STATE'S RESPONSE" SHOULD BE READ WITHOUT REFERENCE TO THE QUESTIONS. THE QUESTIONS ARE INCLUDED SOLELY TO PROVIDE A CROSS-REFERENCE TO THE POTENTIAL OFFEROR THAT SUBMITTED THE QUESTION. QUESTIONS DO NOT FORM A PART OF THE CONTRACT; THE "STATE'S RESPONSE" DOES. ANY RESTATEMENT OF PART OR ALL OF AN EXISTING PROVISION OF THE SOLICITATION IN AN ANSWER DOES NOT MODIFY THE ORIGINAL PROVISION EXCEPT AS FOLLOWS: UNDERLINED TEXT IS ADDED TO THE ORIGINAL PROVISION. STRICKEN TEXT IS DELETED. 02-2A097-1]

- Other Change:

IMPORTANT NOTICE:

Contractor is required to acknowledge receipt of this Addendum by signing below and returning a copy with its Offer.

Q: We have been informed that the specified 430 BBJ Microbicide is no longer available. Do you have an approved alternative?

A: The current, available Biocide to use is "BBJ Mold Control for HVAC Systems and Air Ducts."

Q: Is cleaning of coils required in all barracks or only Stevens?

A: Cleaning of the coils is not necessary, however, if a coil or fan coil unit is identified as being excessively dirty, please note a discrepancy and give the information to the escort from the HVAC shop. Evaporator coil and cleanable filter on the window A/C units must be cleaned if dirty.

Q: Do you have specific guidelines/requirements with regard to COVID 19 precautions?

A: Guidance from The Citadel is available at: <https://today.citadel.edu/covid-19/>

Except as provided herein, all terms and conditions of the Solicitation referenced above remain unchanged and in full force and effect.

SIGNATURE OF PERSON AUTHORIZED TO EXECUTE ON BEHALF OF OFFEROR

Signature: _____

Printed Name & Title: _____

Company Name: _____

Date: _____