



THE CITADEL

Solicitation Number	IFB 21027-SB
Addendum #	1
Date Issued	May 7, 2021
Procurement Officer	Scott Brechtel
Phone	843-953-2737
E-Mail Address	sbrechte@citadel.edu

SOLICITATION TITLE: Commercial Kitchen Equipment

TYPE OF ADDENDUM:

- Change or clarification to the Solicitation’s specifications, requirements, or scope of work.
- Questions posed regarding the Solicitation and their respective answers by The Citadel.

QUESTIONS FROM OFFERORS - AMENDMENT (JUN 2017)

THE SOLICITATION IS AMENDED AS PROVIDED HEREIN. INFORMATION OR CHANGES RESULTING FROM QUESTIONS WILL BE SHOWN IN A QUESTION-AND-ANSWER FORMAT. ALL QUESTIONS RECEIVED HAVE BEEN REPRINTED BELOW. THE “STATE’S RESPONSE” SHOULD BE READ WITHOUT REFERENCE TO THE QUESTIONS. THE QUESTIONS ARE INCLUDED SOLELY TO PROVIDE A CROSS-REFERENCE TO THE POTENTIAL OFFEROR THAT SUBMITTED THE QUESTION. QUESTIONS DO NOT FORM A PART OF THE CONTRACT; THE “STATE’S RESPONSE” DOES. ANY RESTATEMENT OF PART OR ALL OF AN EXISTING PROVISION OF THE SOLICITATION IN AN ANSWER DOES NOT MODIFY THE ORIGINAL PROVISION EXCEPT AS FOLLOWS: UNDERLINED TEXT IS ADDED TO THE ORIGINAL PROVISION. STRICKEN TEXT IS DELETED. 02-2A097-1]

- Other Change:

IMPORTANT NOTICE:

X Contractor is required to acknowledge receipt of this Addendum by signing below and returning a copy with its Offer.

Q: Item # 4 on your Bid Request—Is this for the Ice Maker only, and do you have an existing bin—or will you need an Ice Storage Bin for the ice maker? If this will be placed on an existing bin, please provide the model & S/N.

A: Ice maker only. Existing unit is Follett Ice Device System, model DEV2100SG-72

Q: Please confirm that this ice maker is a water cooled model.

A: Confirmed.

Except as provided herein, all terms and conditions of the Solicitation referenced above remain unchanged and in full force and effect.

SIGNATURE OF PERSON AUTHORIZED TO EXECUTE ON BEHALF OF OFFEROR

Signature: _____

Printed Name & Title: _____

Company Name: _____

Date: _____