



THE CITADEL

Solicitation Number	IFB 22001-JD
Addendum #	1
Date Issued	May 7, 2021
Procurement Officer	James de Luca
Phone	843-953-6861
E-Mail Address	jdeluca@citadel.edu

SOLICITATION TITLE: The Citadel is seeking bids for the renovation / modernization of the elevator located in Duckett hall, per the attached specifications.

TYPE OF ADDENDUM:

- Change or clarification to the Solicitation's specifications, requirements, or scope of work.
- Questions posed regarding the Solicitation and their respective answers by The Citadel.

QUESTIONS FROM OFFERORS - AMENDMENT (JUN 2017)

THE SOLICITATION IS AMENDED AS PROVIDED HEREIN. INFORMATION OR CHANGES RESULTING FROM QUESTIONS WILL BE SHOWN IN A QUESTION-AND-ANSWER FORMAT. ALL QUESTIONS RECEIVED HAVE BEEN REPRINTED BELOW. THE "STATE'S RESPONSE" SHOULD BE READ WITHOUT REFERENCE TO THE QUESTIONS. THE QUESTIONS ARE INCLUDED SOLELY TO PROVIDE A CROSS-REFERENCE TO THE POTENTIAL OFFEROR THAT SUBMITTED THE QUESTION. QUESTIONS DO NOT FORM A PART OF THE CONTRACT; THE "STATE'S RESPONSE" DOES. ANY RESTATEMENT OF PART OR ALL OF AN EXISTING PROVISION OF THE SOLICITATION IN AN ANSWER DOES NOT MODIFY THE ORIGINAL PROVISION EXCEPT AS FOLLOWS: UNDERLINED TEXT IS ADDED TO THE ORIGINAL PROVISION. STRICKEN TEXT IS DELETED. 02-2A097-1]

- Other Change:

IMPORTANT NOTICE:

Contractor is required to acknowledge receipt of this Addendum by signing below and returning a copy with its Offer.

Q: Section 2.15 calls for new cab panels, do you intend for a new ceiling to also be installed? What is the desired ceiling type (i.e. ss island type or t-frame w/ inserts)? Do you intend for the car fan to be replaced? Do you intend for the car doors to be replaced?

A: Ceiling is part of the cab and will need to be replaced along with lighting (LED) and fan, interior doors will need to match cab interior.

Q: Section 2.15 calls for vandal proof buttons in the car operating panel. Is it your intent to include vandal proof buttons in the hall call fixtures too?

A: Yes, minimize troubles with call buttons in or out of the cab.

Q: Currently there are conduit runs behind the pit access ladder. This is not code compliant. Will the elevator contractor be required to reroute this conduit, or will that be the responsibility of others?

A: This will lay with work conducted by The Citadel.

Q: The existing hall call fixtures include position indicators. Is it your intent to include position indicators in the new hall fixtures?

A: Either hall fixtures or above the doors.

Q: Will the existing original job layout and wiring diagrams be provided to the successful offeror?

A: Don't understand the question, but the successful offeror will be supplying the diagrams and pertinent equipment information and manuals to The Citadel.

Q: Is it your intent to retain the existing rating and speed?

A: The current speed I believe is 75 FPM, I would like it to Be 100 FPM. If 75 is the best for the original Motor yes the speed will be maintained.

Q: As a bid alternate, will you consider replacing the 1969 machine with a new Torin geared machine?

A: Provide a separate Cost estimate for consideration, as there is nothing wrong with that motor.

Except as provided herein, all terms and conditions of the Solicitation referenced above remain unchanged and in full force and effect.

SIGNATURE OF PERSON AUTHORIZED TO EXECUTE ON BEHALF OF OFFEROR

Signature:_____

Printed Name & Title:_____

Company Name:_____

Date:_____